

Failure to Develop Initial Inventory or make publicly accessible for Service Line Materials or Make Publicly Accessible

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Lake Barrington Shores Failed to Completely Satisfy an EPA Initial Service Line Inventory Form (Lead and/or Galvanized Service Lines)

Our water system recently violated a drinking water requirement. As our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct this situation.

We were required to develop and make publicly available an initial inventory of service lines connected to our distribution system. **Our system failed to submit this inventory of service lines in the allotted time frame as additional data was required in order to complete the form, and sent to the Illinois Environmental Protection Agency. We have completed the inventory service line list which has been accepted by the IEPA.** The inventory must identify the service line materials as lead galvanized requiring replacement (GRR)¹, lead-status unknown/unknown, or non-lead. Identifying and ultimately removing lead and GRR service lines is an important way to protect public health.

LBS does NOT have nor has ever had Lead or Galvanized water service lines. Our service lines are all PVC plastic and or Copper, which are both EPA approved. The above noted inventory is a comprehensive record of all water service lines that our system feeds, please find the list on the [www.lakebarringtonshores.org] website.

**Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems. **

What should I do?

Listed below are some steps you can take to reduce your exposure to lead:

- **Learn what your service line material is.** Contact us at **[847/382-1660 or info@lbs-hoa.org]** or a licensed plumber to determine if the pipe that connects your home to the water main (called a service line) is made from lead, galvanized, or other materials. Protect Your Tap: A quick check for lead is the EPA's online step by step guide to learn how to find lead pipes in your home (www.epa.gov/pyt). **LBS does NOT have any Lead or Galvanized service lines.**
- **Learn about construction in your neighborhood.** Unless your service line is not made of lead or galvanized you should be aware of any nearby construction or maintenance work that could

¹ A galvanized requiring replacement service line is a galvanized service line that is or was potentially downstream of a lead service line.

disturb the line. Ground tremors from construction may suddenly cause more lead to be released from lead or galvanized service lines in the area.

- **Use your filter properly.** Using a filter can reduce lead in drinking water. If you use a filter, make sure you use a filter certified to remove lead. Read the directions to learn how to properly install and use your cartridge and when to replace it. Using the cartridge after it has expired can make it less effective at removing lead. Do not run hot water through the filter.
- **Clean your aerator.** Regularly remove and clean your faucet's screen (also known as an aerator). Sediment, debris, and lead particles can collect in your aerator. If lead particles are caught in the aerator, lead can get into your water.
- **Use cold water.** Use only cold water for drinking, cooking, and making baby formula. Remember, boiling water does not remove lead from water.
- **Run your water.** The more time water has been sitting in pipes, the more lead it may contain. Before drinking, flush your home's pipes by running the tap, taking a shower, doing laundry, or doing a load of dishes. The amount of time to run the water will depend on whether your home has a lead service line or not, and the length of the lead service line. Residents should contact their water utility for recommendations about flushing times in their community.
- **Have your water tested.** Contact your water utility to have your water tested and to learn more about the lead levels in your drinking water.

What does this mean?

Service line inventories are the foundation from which water systems take action to address a significant source of lead in drinking water. Establishing an inventory of service line materials and identifying the location of lead and GRR service lines is a key step in getting them replaced and protecting public health. Typically, lead enters water supplies by leaching from lead pipes, brass faucets, plumbing with leaded solder, and other plumbing components containing lead. In homes with lead pipes that connect the home to the water main, also known as lead service lines, these pipes are typically the most significant source of lead in the water. Lead pipes are more likely to be found in older cities and homes built before 1986. Service lines made of galvanized iron or steel that are (or were previously) downstream of lead service lines are classified as galvanized requiring replacement (GRR) because galvanized service lines that are or ever were downstream from an LSL can adsorb lead and contribute to lead in drinking water. Identifying and ultimately removing lead and GRR service lines is an important way to protect public health.

What is being done?

LBS does NOT have any Lead or Galvanized supply lines and is NOT required to take any further action.

For more information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's Web site at <http://www.epa.gov/lead> or contact your health care provider.

For more information, please contact the **Water Department** at **847/382-1660** or **info@lbs-hoa.org**

**Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail. **

This notice is being sent to you by Lake Barrington Public Works, Water System ID#: [**IL0975520**].



Illinois Environmental Protection Agency

2520 West Iles Avenue • P.O. Box 19276 • Springfield, Illinois • 62794-9276 • 217-782-3397

JB Pritzker, Governor

James Jennings, Acting Director

217/785-0561

April 29, 2026

06G

Tom Latta
64 Old Barn Rd
Lake Barrington, IL 60010

Re: IL0975520, LAKE BARRINGTON SHORES SUBDIVISION - 2026 Service Line Material Inventory Acceptance

Water System Official:

Pursuant to the Illinois Environmental Protection Act Section 17.12 – Lead service line notification and replacement act and Title 35 Il. Adm. Code 611.354, each community water supply (Supplier) must develop an inventory identifying the materials composition for all service lines connected to its distribution system.

This letter is to confirm that the 2026 material inventory submission for your system has been accepted.

As a reminder, if your system has lead service lines, your lead and copper monitoring site plan must consist of only Site served by a lead service line. Failure to collect from only sites served by a lead service line (if lead service lines are present) represents a violation of the Illinois Pollution Control Board regulations.

Sincerely,

A handwritten signature in black ink that reads "Adam J Nutt".

Adam Nutt
Compliance Assurance Section
Division of Public Water Supplies
Bureau of Water

cc: BRADLEY EMRUD

2125 S. First Street, Champaign, IL 61820 • 217-278-5800
1101 Eastport Plaza Dr., Suite 100, Collinsville, IL 62234 • 618-346-5120
595 S. State Street, Elgin, IL 60123 • 847-606-3131
412 SW Washington Street, Suite D, Peoria, IL 61602 • 309-671-3022

115 S. LaSalle Street, Suite 2203, Chicago, IL 60603
9511 Harrison Street, Des Plaines, IL 60016 • 847-294-4000
2309 W. Main Street, Suite 116, Marion, IL 62959 • 618-993-7200
4302 N. Main Street, Rockford, IL 61103 • 815-987-7760

Please print on recycled paper.